

Signet 9950 Modbus Module



3-9950-395.090 Rev 0 02/19

Installation and Programming



Description

The Modbus Module, 3-9950.305-M (159 001 905), allows the Signet 9950 SmartPro Transmitter to connect to a Modbus master compatible device. The Modbus Module supports RTU modes over serial RS485 communication links. The Modbus Module has an internal programmable network termination for the communication link enabled by Modbus command.

Specifications

- Modbus RTU mode
- 1200, 2400, 4800, 9600, 19200. 38400, 57600, and 115000 Baud rates, 19200 is default Baud rate.
- Parity can be selected as Even, Odd, or None, Even is default Parity.
- Modbus Address 1 to 247, 95 is default Modbus Address.
- Data Bits. RTU Mode 8 Data bits.
- Stop Bits. RTU Mode 1 Stop bit.
- Endian can be selected as either Big Endian, or Little Endian, Big Endian is the Default.

Selectable internal terminating resistor for Modbus communication, default is resistor disconnected.

Start Up Communication Parameters

Start Up Communication Parameters

The Modbus communication parameters for 9950 Gen 3 transmitters are set via the 9950 front panel or over a Modbus connection.

The Modbus module is shipped from the factory, and can be reset in the field, with the following communication parameters. See the Communication Setting Programming flow chart.

Setting	Default Value
Modbus Address	95
Modbus Network Termination	Off
Modbus Mode	RTU
Baud Rate	19200
Parity	Even
Endian	Big Endian

• [English](#)

Warranty Information

Refer to your local Georg Fischer Sales office for the most current warranty statement.

All warranty and non-warranty repairs being returned must include a fully completed Service Form and goods must be returned to your local GF Sales office or distributor. Product returned without a Service Form may not be warranty replaced or repaired.

Signet products with limited shelf-life (e.g. pH, ORP, chlorine electrodes, calibration solutions; e.g. pH buffers, turbidity standards or other solutions) are warranted out of box but not warranted against any damage, due to process or application failures (e.g. high temperature, chemical poisoning, dry-out) or mishandling (e.g. broken glass, damaged membrane, freezing and/or extreme temperatures).

Product Registration

Thank you for purchasing the Signet line of Georg Fischer measurement products.

If you would like to register your product(s), you can now register online in one of the following ways:

- Visit our website **www.gfsignet.com**. Under **Service and Support** click on **Product Registration Form**
- If this is a pdf manual (digital copy), [click here](#)

Safety Information



CAUTION

Exercise care when installing module.
Do not bend connecting pins.
Align pins and connectors then push module firmly into place.


Avoid Electrostatic Discharge (ESD)

- Minimize handling of module to reduce the possibility of damage due to ESD.
- Handle module by the edges.
- Never touch any exposed circuitry or contacts.
- Wear an anti-static wristband, stand on an anti-static mat, or keep one hand touching a properly grounded pipe or other properly grounded piece of metal when handling module.

	Caution / Warning / Danger Indicates a potential hazard. Failure to follow all warnings may lead to equipment damage, injury, or death
	Electrostatic Discharge (ESD) / Electrocutation Danger Alerts user to risk of potential damage to product by ESD, and/or risk of potential of injury or death via electrocution.
	Personal Protective Equipment (PPE) Always utilize the most appropriate PPE during installation and service of Signet products.

Wiring

Modbus Module



Installation

For future reference, for each installation, it is recommended to record the part number and serial number of each of the components listed here:

Facility Tag Number or System ID (user assigned):	_____	
Base unit	3-9950-_____	S/N _____
Relay Module	3-9950.393-_____	S/N _____
Single Channel Cond./Resist. Module	3-9950.394-_____	S/N _____
Dual Channel 4-20 Current Loop Out. Module	3-9950.398-_____	S/N _____
Dual Channel Conductivity Module	3-9950.394-2_____	S/N _____
Modbus Module	3-9950.395-M_____	S/N _____

Modbus Menus

OPTION Menu

MODBUS MODULE NONE	Select the location of the Modbus Module, None (Default), Module 1, or Module 2 Important: You must select the location of the Modbus Module for proper operation.
MODBUS COMMUNICATION SETTINGS ->	Press the Right Arrow key to change the settings of the Modbus Module

Modbus Communication Setting Menu

MODBUS ADDRESS 95	Set the Modbus address of the 9950. The default address is 95
NETWORK TERMINATION NO	The 9950 Modbus Module has an electronic termination network. The Termination can be activated by setting the value to Yes. The default value is No (the termination is off).
MODBUS BAUD RATE 19.2 K	Set the baud rate of the Modbus network. The default value is 19.2K baud, 19200 baud.
MODBUS PARITY ODD	Set the parity of the Modbus network. The default value is Even parity.
MODBUS ENDIAN BIG	Set the arrangement for how the 9950 transmits floating point, real, numbers. The default value is Big Endian.
RESET TO DEFAULT NO	Reset all Modbus setting to the default values.
ACTIVATE SETTINGS NO	Activate setting send all the change to the default parameter to the Modbus module. If you do not activate the setting the configured setting will not take effect until after the 9950 is power cycled.

Modbus Remote Update

MODBUS REMOTE UPDATE NO	Setting Modbus Remote update to Yes allows remote Modbus device to change the settings on the 9950. Setting Modbus Remote Update to No prevents remote devices from make any changes to the 9950. Remote device will still be able to read all of the Modbus parameters.
-------------------------------	--

Modbus Register Map

Live Reading

Register	Size	Read/Write	Data Type	Description
40001	2	Read	UDINT	Channel 1 Status
40003	2	Read	Float	Channel 1 Primary Reading
40005	2	Read	Float	Channel 1 Secondary Reading
40007	1	Read	UINT	Channel 1 Measurement Type
40008	1	Read	UINT	Channel 1 Primary Units of Measure Code
40009	1	Read	UINT	Channel 1 Secondary Units of Measure Code
40010	2	Read	UDINT	Channel 2 Status
40012	2	Read	Float	Channel 2 Primary Reading
40014	2	Read	Float	Channel 2 Secondary Reading
40016	1	Read	UINT	Channel 2 Measurement Type
40017	1	Read	UINT	Channel 2 Primary Units of Measure
40018	1	Read	UINT	Channel 2 Secondary Units of Measure

Live Readings: Binary Inputs

Register	Size	Read/Write	Data Type	Description
40201	2	Read	UDINT	Binary Input Module Status
40203	1	Read	UINT	Binary Inputs 1 through 4. Bits 0 through 3, other are fixed at 0

Live Readings: Derived Functions

Register	Size	Read/Write	Data Type	Description
40301	2	Read	UDINT	Derived Function 1 Status
40303	2	Read	Float	Derived Function 1 Value
40305	2	Read	UDINT	Derived Function 2 Status
40307	2	Read	Float	Derived Function 2 Value
40309	2	Read	UDINT	Derived Function 3 Status
40311	2	Read	Float	Derived Function 3 Value
40313	2	Read	UDINT	Derived Function 4 Status
40315	2	Read	Float	Derived Function 4 Status

Live Readings: Current Loop Outputs

Register	Size	Read/Write	Data Type	Description
40401	2	Read	UDINT	Current Loop 1 Status
40403	2	Read	Float	Current Loop 1 Output (mA)
40405	2	Read	UDINT	Current Loop 2 Status
40407	2	Read	Float	Current Loop 2 Output (mA)
40409	2	Read	UDINT	Current Loop MOD1 A Status
40411	2	Read	Float	Current Loop MOD1 A Output (mA)
40413	2	Read	UDINT	Current Loop MOD1 B Status
40415	2	Read	Float	Current Loop MOD1 B Output (mA)
40417	2	Read	UDINT	Current Loop MOD2 A Status
40419	2	Read	Float	Current Loop MOD2 A Output (mA)
40421	2	Read	UDINT	Current Loop MOD2 B Status
40423	2	Read	Float	Current Loop MOD2 B Output (mA)

Live Readings: Relays

Register	Size	Read/Write	Data Type	Description
40501	2	Read	UDINT	Relay 1 Status
40503	1	Read	UINT	Relay 1 State
40504	2	Read	Float	Relay 1 Value
40506	2	Read	UDINT	Relay 2 Status
40508	1	Read	UINT	Relay 2 State
40509	2	Read	Float	Relay 2 Value
40511	2	Read	UDINT	Relay 3 Status
40513	1	Read	UINT	Relay 3 State
40514	2	Read	Float	Relay 3 Value
40516	2	Read	UDINT	Relay 4 Status
40518	1	Read	UINT	Relay 4 State
40519	2	Read	Float	Relay 4 Value

Live Readings: Module Status

Register	Size	Read/Write	Data Type	Description
40601	2	Read	UDINT	Module 1 Status
40603	2	Read	UDINT	Module 2 Status

Live Readings: Channel 1 and Channel 2 Registers

Register	Size	Read/Write	Data Type	Description
40901	1	Read/Write	UINT	Channel 1 Control Register
40902	1	Read/Write	UINT	Channel 2 Control Register


Communication Settings

Register	Size	Read/Write	Data Type	Description
49001	1	Read/Write	UINT	Modbus Address 1 to 247 (Default 95)
49002	1	Read/Write	UINT	Network Termination, 1 = ON 0 = Off (Default 0)
49003	1	Read/Write	UINT	Modbus Mode 0 = Modbus RTU, 1 = Modbus ASCII (Default 0)
49004	1	Read/Write	UINT	Baud Rate 0 = 1200, 1 = 2400, 2 = 4800, 3 = 9600, 4 = 19200, 5 = 38400, 6 = 57600, 7 = 115200 (Default 4)
49005	1	Read/Write	UINT	Parity 0 = No Parity, 1 = Odd Parity, 2 = Even Parity (Default 2)
49006	1	Read/Write	UINT	Endian 0 = Big Endian, 1 = Little Endian (Default 0)
49030	1	Read/Write	UINT	Write 0 (zero) to save registers and activate new settings

Communication Diagnostic Registers

Register	Size	Read/Write	Data Type	Description
49101	1	Read	UINT	Bus Message Counter
49102	1	Read	UINT	Bus Message Error Counter
49103	1	Read	UINT	Slave Exception Counter
49104	1	Read	UINT	Slave Message Counter
49105	1	Read	UINT	Slave No Response Counter
49106	1	Read	UINT	Slave NAK Counter
49107	1	Read	UINT	Slave Busy Counter
49108	1	Read	UINT	Bus Character Overrun Counter
49109	1	Read/Write	UINT	Clear Counters and Registers 0 to 1 Clears all
49110	2	Read	UINT	Seconds since Power Up
49112	1	Read	UINT	9950 Messages Processed
49113	1	Read	UINT	9950 Message Errors
49114	1	Read	UINT	Modbus Messages Processed
49115	1	Read	UINT	Modbus Message Errors

Communication Settings Programming



Readings / Sensors

Instrument Type	Measurement Type Channel 1 Reg 40007 Channel 2 Reg 40016	Primary Channel 1 Reg 40003 Channel 2 Reg 40012	Secondary Channel 1 Reg 40005 Channel 2 Reg 40014
Factory ¹	0x0000	NA	NA
None ¹	0x0001	NA	NA
Flow	0x0002	Flow	Totalizer ²
pH	0x0003	pH	Temperature
ORP	0x0004	ORP	Raw mV User must set bit 10 in Control Register to have raw mV returned as secondary measurement. Otherwise, the 9950 will set secondary measurement to zero.
Cond/Res	0x0005	Cond/Res	Temperature
Pressure	0x0006	Pressure	NA
Level/Volume	0x0007	Level	Volume
Temperature	0x0008	Temperature	NA
4 to 20 mA Input	0x0009	Scaled Input	Raw mA User must set bit 10 in Control Register to have raw mA returned as secondary measurement. Otherwise, the 9950 will set secondary measurement to zero.
Salinity	0x000A	Salinity	Temperature
Dissolved Oxygen	0x000B	Dissolved Oxygen	Temperature

¹ Factory and None types do not update the Primary or Secondary readings.

² The Totalizer is the Totalizer set to be displayed in the view menu. This can be changes in the Input Menu, Totalizer Display. The totalizer type, permanent or resettable, is indicated in the Channel Status Register bits 19 and 20.

Programming Map

Channel Status Registers

Channel 1 Registers 40001

Channel 2 Registers 40010

Register.Bit	Description
400xx.0	Sensor Reading is Good, No Errors
400xx.1	Wrong Sensor Connected or Wrong Module Connected
400xx.2	Check Sensor
400xx.3	Missing Sensor or Missing Module
400xx.4	Sensor Error
400xx.5	Secondary Reading is Totalizer
400xx.6	Secondary Reading Not Available
400xx.7	Not Used (Always zero)
400xx.8	9950 Communication Active
400xx.9	Not Used (Always one)
400xx.10	Device Using Default Communication Parameters
400xx.11	No Flow Detected (Flow), Expired Cap (Dissolved Oxygen), Broken Glass (pH 2751)
400xx.12	Missing Cap (Dissolved Oxygen), Missing Probe (pH, ORP, and Conductivity)
400xx.13	Sensor Busy (pH 2751, Conductivity 2850)
400xx.14	Conductivity Over Range (Conductivity), Current Under Range < 3.6 mA (4 to 20 mA Input)
400xx.15	Conductivity Calculation Error (Conductivity), Current Over Range > 22 mA (4 to 20 mA Input)
400xx.16	Wrong Probe (pH or ORP)
400xx.17	Permanent Totalizer Rolled Over
400xx.18	Resettable Totalizer Rolled Over (Flow) Secondary Reading is Reference Impedance (pH 2751)
400xx.19	Secondary Reading is Permanent Totalizer (Flow) Secondary Reading is Raw mV (pH or ORP) Secondary Reading is Cap Expiration Timestamp (Dissolved Oxygen)
400xx.20	Secondary Reading is Resettable Totalizer (Flow) Secondary Reading is Glass Impedance (pH 2751) Secondary Reading is Current Time Stamp (Dissolved Oxygen)
400xx.21	Secondary Reading is Temperature
400xx.22	Calibration in Process
400xx.23	Outputs are Held
400xx.24	System Reset/Power Up
400xx.25	System Offline
400xx.26	Read Only Mode
400xx.27 – 400xx.31	Not Used

Binary Input Status

Register.Bit	Description
40201.0	Good No Errors, Module Present
40201.1	Wrong Module
40201.2	Not Used
40201.3	Missing Module
40201.4	Not Used
40201.5	Not Used
40201.6	Not Used
40201.7	Not Used
40201.8	9950 Communication Active
40201.9	Not Used
40201.10	Using Default Communication Parameters
40201.11	Not Used
40201.12	Not Used
40201.13	Not Used
40201.14	Not Used
40201.15	Not Used
40201.16	Not Used
40201.17	Not Used
40201.18	Not Used
40201.19	Not Used
40201.20	Not Used
40201.21	Not Used
40201.22	Not Used
40201.23	Not Used
40201.24	System Reset / Power Up
40201.25	System Offline
40201.26	Read Only Mode
40201.27 – 40201.31	Not Used

Programming Map

Derived Function Status Registers

Derived Function 1 Status Register 40301

Derived Function 2 Status Register 40305

Derived Function 3 Status Register 40309

Derived Function 4 Status Register 40313

Register.Bit	Description
403xx.0	Good, No Errors
403xx.1	Divide by Zero
403xx.2	Measurement 1 Error
403xx.3	Measurement 2 Error
403xx.4	Not Used
403xx.5	Not Used
403xx.6	Not Used
403xx.7	Not Used
403xx.8	9950 Communication Active
403xx.9	Not Used
403xx.10	Device using Default Communication Parameters
403xx.11	Not Used
403xx.12	Not Used
403xx.13	Not Used
403xx.14	Not Used
403xx.15	Not Used
403xx.16	Not Used
403xx.17	Not Used
403xx.18	Not Used
403xx.19	Not Used
403xx.20	Not Used
403xx.21	Not Used
403xx.22	Calibration in Process
403xx.23	Outputs are Held
403xx.24	System Reset/Power Up
403xx.25	System Offline
403xx.26	Read Only Mode
403xx.27 – 403xx.31	Not Used

Loop Status Registers

Loop 2 Status Register 40405

Loop Module 1 A Status Register 40409

Loop Module 1 B Status Register 40413

Loop Module 2 A Status Register 40417

Loop Module 2 B Status Register 40421

Register.Bit	Description
404xx.0	Good, No Errors
404xx.1	Missing Module
404xx.2	Loop in Use
404xx.3	Measurement Error
404xx.4	Loop sending Error Current
404xx.5	Not Used
404xx.6	Not Used
404xx.7	Not Used
404xx.8	9950 Communication Active
404xx.9	Not Used
404xx.10	Device using Default Communication Parameters
404xx.11	Not Used
404xx.12	Not Used
404xx.13	Not Used
404xx.14	Not Used
404xx.15	Not Used
404xx.16	Not Used
404xx.17	Not Used
404xx.18	Not Used
404xx.19	Not Used
404xx.20	Not Used
404xx.21	Loop in Manual Mode
404xx.22	Calibration in Process
404xx.23	Outputs are Held
404xx.24	System Reset/Power Up
404xx.25	System Offline
404xx.26	Read Only Mode
404xx.27 – 404xx.31	Not Used

Relay Status Registers

Relay 1 Status Register 40501

Relay 2 Status Register 40506

Relay 3 Status Register 40511

Relay 4 Status Register 40516

Register.Bit	Description
405xx.0	Good, No Errors
405xx.1	Missing Module
405xx.2	Relay in Use
405xx.3	Measurement 1 Error
405xx.4	Measurement 2 Error
405xx.5	Measurement 3 Error
405xx.6	Not Used
405xx.7	Not Used
405xx.8	9950 Communication Active
405xx.9	Not Used
405xx.10	Device using Default Communication Parameters
405xx.11	Not Used
405xx.12	Not Used
405xx.13	Not Used
405xx.14	Not Used
405xx.15	Not Used
405xx.16	Not Used
405xx.17	Not Used
405xx.18	Not Used
405xx.19	Not Used
405xx.20	Not Used
405xx.21	Manual Mode
405xx.22	Calibration in Process
405xx.23	Outputs are Held
405xx.24	System Reset/Power Up
405xx.25	System Offline
405xx.26	Read Only Mode
405xx.27 – 405xx.31	Not Used

Module Status Registers

Module 1 Status Register 40601

Module 2 Status Register 40602

Register.Bit	Description
4060x.0	Good, No Errors
4060x.1	Missing Module
4060x.2	Module in Use
4060x.3	Measurement 1 Error
4060x.4	Measurement 2 Error
4060x.5	Measurement 3 Error
4060x.6	Not Used
4060x.7	Not Used
4060x.8	9950 Communication Active
4060x.9	Not Used
4060x.10	Device using Default Communication Parameters
4060x.11	Not Used
4060x.12	Not Used
4060x.13	Not Used
4060x.14	Not Used
4060x.15	Not Used
4060x.16	Not Used
4060x.17	Not Used
4060x.18	Not Used
4060x.19	Not Used
4060x.20	Not Used
4060x.21	Manual Mode
4060x.22	Calibration in Process
4060x.23	Outputs are Held
4060x.24	System Reset/Power Up
4060x.25	System Offline
4060x.26	Read Only Mode
4060x.27 – 4060x.31	Not Used

Programming Map

Module Status Registers

Module 1 Status Register 40601

Module 2 Status Register 40602

Register.Bit	Description
4090x.0	Transition (0 to 1) Reset Resettable Totalizer (Flow)
4090x.1	Transition (0 to 1) Reset Permanent Totalizer Roll Over Bit (Flow)
4090x.2	Transition (0 to 1) Reset Resettable Totalizer Roll Over Bit (Flow)
4090x.3	Transition (0 to 1) Initiate Glass Impedance Measurement (pH 2751)
4090x.4	Transition (0 to 1) Initiate Reference Impedance Measurement (pH or ORP 2751)
4090x.5	Not Used
4090x.6	Not Used
4090x.7	Not Used
4090x.8	Not Used
4090x.9	Not Used
4090x.10	Set Bit to 1 to read raw mV as Secondary Measurement (pH or ORP) Set Bit to 1 to read Measurement Cap Expiration Date as Secondary Measurement (Dissolved Oxygen)
4090x.11	Set Bit to 1 to read Glass Impedance as Secondary Measurement (pH 2751) Set Bit to 1 to read Current Time as Secondary Measurement (Dissolved Oxygen)
4090x.12	Set Bit to 1 to read Reference Impedance as Secondary Measurement (pH or ORP 2751)
4090x.13	Not Used
4090x.14	Not Used
4090x.15	Transition (0 to 1) to Clear System Reset / Power Up Bit

Format (Byte Orders)

Floats

Register	Data	Bytes
IEEE-754 Float 0x570A4318		
Value 152.34		
49006	0	Big Endian
40003	0x570A	C D
40004	0x4318	A B
49006	1	Little Endian
40003	0x4318	AB
40004	0x570A	CD

Units of Measure

Unit of Measure	Code	Description
Flow (Primary)		
AF/D	27323	Acre-Feet / Day
AF/H	27067	Acre-Feet / Hour
AF/M	26811	Acre-Feet / Minute
AF/S	26555	Acre-Feet / Second
GPS	26390	Gallons per Second
GPM	26640	Gallons per Minute
GPH	27016	Gallons per Hour
GPD	27371	Gallon per Day
LPS	26392	Liters per Second
LPM	26641	Liters per Minute
LPH	27018	Liters per Hour
LPD	27313	Liters per Day
M3/S	26396	Cubic Meters per Second
M3/M	26755	Cubic Meters per Minute
M3/H	26899	Cubic Meters per Hour
M3/D	27165	Cubic Meters per Day
ml/S	26544	milliliters per Second
ml/M	26800	milliliters per Minute
ml/H	27056	milliliters per Hour
ml/D	27312	milliliters per Day
FT3/S	26394	Cubic Feet per Second
FT3/M	26639	Cubic Feet per Minute
FT3/H	27010	Cubic Feet per Hour
FT3/D	27163	Cubic Feet per Day
MG/D	27159	Million Gallons per Day
All Others	252	All other flow units
Flow Totalization (Secondary)		
AF	17679	Acre-Feet
FT3	17520	Cubic Feet
M3	17541	Cubic Meters
Gal	17448	Gallons
L	17449	Liters
mL	17650	Milliliter
All other Units	252	

Programming Map

Units of Measure

Unit of Measure	Code	Description
pH (Primary)		
pH	20795	pH
pH Temperature (Secondary)		
Temperature C	16416	Degrees Celsius
Temperature F	16417	Degrees Fahrenheit
ORP (Primary and Secondary)		
mV	21284	Millivolts
Conductivity (Primary)		
uS	22329	microSiemens
mS	22338	milliSiemens
PPM	23179	Parts per Million
PPB	23209	Parts per Billion
KOhms	21932	Kilo Ohms
MOhms	21933	Mega Ohms
Conductivity Temperature (Secondary)		
Temperature C	16416	Degrees Celsius
Temperature F	16417	Degrees Fahrenheit
Pressure		
PSI	16646	Pounds per Square Inch
Bar	16647	Bars
KPa	16652	Kilopascals
Level/Volume (Level)		
FT	17708	Feet
IN	17711	Inches
M	17709	Meters
CM	17712	Centimeters
Level/Volume (Volume)		
FT3	17520	Cubic Feet
IN3	17521	Cubic Inches
M3	17451	Cubic Meters
CM3	17648	Cubic Centimeters
GAL	17448	Gallons
LIT	17449	Liters
Lb	18239	Pounds
KG	18237	Kilograms
Temperature		
C	16416	Degrees Celsius
F	16417	Degrees Fahrenheit

Programming Map

Units of Measure

4 to 20 mA Input		
mA	21543	Raw 4 – 29 mA Input Current
Salinity (Primary)		
PPT	23210	Parts per Thousand
Salinity Temperature (Secondary)		
C	16416	Degrees Celsius
F	16417	Degrees Fahrenheit
Dissolved Oxygen (Primary)		
PPM	139	Parts per Million
% SAT	57	Percent
TOR	16653	Torr
Dissolved Oxygen Temperature (Secondary)		
C	16416	Degrees Celsius
F	16417	Degrees Fahrenheit
Other		
nA	21674	Nanoamp
FNU	25002	Formazin Nephelometric Units
FTU	25003	Formazin Turbidity Units
NTU	25004	Nephelometric Turbidity Units
4 to 20 mA Scaled Input		
%Sat	57	Percent Saturation
AF	17679	Acre Feet
AF/D	27323	Acre Feet per Day
AF/H	27067	Acre Feet per Hour
AF/M	26811	Acre Feet per Minute
AF/S	26555	Acre Feet per Second
Bar	16647	Bar
C	16416	Degree C
CM	17712	Centimeter
F	16417	Degree F
FNU	25002	
FT	17708	Feet
FT3	17520	Cubic Feet
F3/D	27163	Cubic Feet per Day
F3/H	27010	Cubic Feet per Hour
F3/M	26639	Cubic Feet per Minute
F3/S	26394	Cubic Feet per Second
FTU	25003	
Gal	17448	Gallons
GPD	27371	Gallons per Day
GPH	27016	Gallons per Hour
GPM	26640	Gallons per Minute
GPS	26390	Gallons per Second
IN	17711	Inches

Programming Map

Units of Measure

KG	18237	Kilogram
KOhm	21923	Kilo-Ohm
KPa	16652	Kilo-Pascal
L	17449	Liters
LB	18239	Pound
Liters	17449	Liters
LPD	27313	Liters per Day
LPH	27018	Liters per Hour
LPM	26641	Liters per Minute
LPS	26392	Liters per Second
mA	21543	milliamp
M	17709	Meters
M3	17451	Cubic Meters
M3/D	27165	Cubic Meters per Day
M3/H	26899	Cubic Meters per Hour
M3/M	26755	Cubic Meters per Minute
M3/S	26396	Cubic Meters per Second
MG/D	27159	Millions of Gallons per Day
ML/D	27161	Millions of Liters per Day
uS	22328	microSiemen
ml	17650	milliliter
ml/D	27312	milliliter per Day
ml/H	27056	milliliter per Hour
ml/M	26800	milliliter per Minute
ml/S	26544	milliliter per Second
MOhm	21930	Mega-Ohm
mS	22338	milliSiemen
mV	21284	millivolt
nA	21674	nanoAmp
NTU	25004	
ORP	21284	ORP
pH	20795	pH
PPB	23209	Parts per Billion
PPM	23179	Parts per Million
PPT	23210	Parts per Thousand
PSI	16646	Pounds per Square Inch
TORR	16653	

Ordering Information

Part Number	Code	Description
3-9950.395-M	159 001 905	Modbus Module

For installation information, please download the Installation and Programming manual at www.gfsignet.com



Georg Fischer Signet LLC, 3401 Aero Jet Avenue, El Monte, CA 91731-2882 U.S.A. • Tel. (626) 571-2770 • Fax (626) 573-2057
For Worldwide Sales and Service, visit our website: www.gfsignet.com • Or call (in the U.S.): (800) 854-4090
For the most up-to-date information, please refer to our website at www.gfsignet.com